

# Intertek ETL SEMKO

September 27, 2005


Mr. Adam Gillis  
Hart & Cooley  
American Metal Products  
500 East 8<sup>th</sup> Street  
Holland, MI 49423

Subject: Use of American Metal Products AmeriVent Direct Vent Venting Systems on DV appliances.

Dear Mr. Gillis,

Intertek Testing Services NA, Inc. (Intertek) has evaluated the American Metal Products AmeriVent Direct Vent Venting Systems for construction, leakage, and for combustion on various direct vent appliances for compliance with UL Subject 2112-2000 and applicable sections of ANSI Z21.88-2002 • CSA 2.33-2002. As a result of these evaluations, Intertek has deemed the American Metal Products AmeriVent Direct Vent Venting Systems are acceptable for use on all applicable gas direct vent appliances listed with the Warnock Hersey mark. All manufacturers with an appliance listed with a Warnock Hersey mark who wish to accept the use of the American Metal Products AmeriVent Direct venting on their product, must submit either a revised instruction manual or an appendix to an existing instruction manual indicating the use of the American Metal Products AmeriVent Direct venting to Intertek for review.

Sincerely,



---

Brian Ziegler  
Engineering Technician



**Intertek Testing Services NA, Inc.**

8431 Murphy Drive, Middleton, WI 53562

Telephone: 608-836-4400 Fax: 608-831-9279 Web: [www.intertek-etlsemko.com](http://www.intertek-etlsemko.com)