


<b>SUBMITTAL DRAWING</b>	JOB NAME: _____ LOCATION: _____ ARCHITECT: _____ ENGINEER: _____ CONTRACTOR: _____	<b>Amerivent Direct Vent</b> VERTICAL CAP 4" & 5" DIAMETERS <hr/> DRAWING #: B7-18
DATE: 05/03/05		
SUBMITTED BY: _____		



PART NO.	SIZE	ø A	HEIGHT B
4DVC	4"X6-5/8"	9-1/4"	9"
5DVC	5"X8"	11-1/4"	9-1/2"



• **MATERIAL**  
 OUTER PIPE – MIN., .018 THICK, GALVANIZED STEEL  
 INNER PIPE – MIN., .012 THICK, TYPE 430 STAINLESS STEEL